

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18
Single user license only. Copying and networking prohibited. This is subject to the END USER LICENCE AGREEMENT.

Formaldehyde emission of building boards Test method-desiccator method

JIS A 1460 : 2021

Revised on February 22, 3rd year of Reiwa

Deliberation by Japanese Industrial Standards Committee

(Published by the Japanese Standards Association)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

A 1460: 2021

Japanese Industrial Standards Committee Standards Section 1 Building Technology Expert Committee Composition Table

	Full name	Affiliation
(Chairman of the committee)	Hiroshi	National Research and Development Corporation Building Research Institute
(Committee)	Akatsuki Ueki	Ministry of Land, Infrastructure, Transport and Tourism Minister's Secretariat Repair Department
	Tadashi Kage	National Research and Development Corporation Building Research Institute
	Naoyuki Koshiishi	Architectural Institute of Japan (Waseda University)
	Qing dynasty	Tsuyoshi University of Tokyo
	Kiyono	Ming Japan Federation of Housing Organizations (Mitsui Home Co., Ltd.)
	Shinichi Tanabe	Waseda University
	Kaori Nagai	Nihon University
	original	Tomohiko Insulation / heat insulation standard council
	Takaharu Fukuda	Japan Federation of Construction Contractors (Kajima Construction Co., Ltd.)
	Fujino Tamae	Housewives Association (Fujino Atelier First Class Architect Office)
	Koji Mano	General Incorporated Foundation Building Material Testing Center
	Mariko Murakawa	Japan Consumer Affairs Advisor / Consultant
		Counselor Association (Kamakura City Consumer Affairs Center)
	Naruhito Yamazaki	Japan Housing Finance Agency
	Kaori Yoshida	T & T Partners Law Firm

Chief Officer: Minister of Economy, Trade and Industry
 Issuance: 2001.3.20 Amendment: Reiwa 3.2.22

Publication date: Reiwa 3.2.22

Cooperator of drafting: Building Material Testing Center

(JL Nihonbashi Building, 1-10-15 Nihonbashi Horidome-cho, Chuo-ku, Tokyo 103-0012 TEL 03-3527-2133)

Deliberation Subcommittee: Japanese Industrial Standards Committee Standards Subcommittee (Chairman Shinsuke Sakai)

Deliberation Special Committee: Building Technology Special Committee (Chairman Hiroshi Ito)

If you have any opinions or questions about this standard, please contact the above drafting cooperator or the International Standards Division, Industrial Technology and Environment Bureau, Ministry of Economy, Trade and Industry (〒100-8901 Please contact 1-3-1 Kasumigaseki, Chiyoda-ku, Tokyo E-mail: jisc@meti.go.jp or FAX 03-3580-8625).

According to the provisions of the Industrial Standardization Law, the Japanese Industrial Standards shall be examined by the Japanese Industrial Standards Committee by the day when at least five years have passed. It will be submitted to the agenda and will be promptly confirmed, revised or abolished.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

A 1460: 2021

1 Scope of application
 2 Quotation standard
 3 Terms and Definitions
 4 Principle of the test
 5 General conditions
 5.1 Test environment
 5.2 Common conditions
 6 Equipment and equipment
 7 Preparation of Reagents
 8 Test Pieces
 8.1 Cutting out test pieces
 8.2 Dimensions and number of test pieces
 8.3 Curing 7
 9 Test method
 9.1 Preparation for the exam
 9.2 Start of emission test
 9.3 Condition monitoring of test conditions
 9.4 Test time
 9.5 Collection of test solution
 9.6 Measurement of formaldehyde concentration in test solution 9
 9.7 Creating a calibration curve
 9.8 Calculations
 9.9 Display of test results
 10 Report 10
 Annex A (Reference) Example of test report
 Annex B (Reference) New and old comparison table regarding technically important revisions ... 12
 Solution

(1)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

A 1460: 2021

Preface

This standard was revised by the Minister of Economy, Trade and Industry in Japan after deliberation by the Japanese Industrial Standards Committee based on the Industrial Standardization Law. It is an industrial standard. As a result, **JIS A 1460** : 2015 was amended and replaced by this standard.

This standard is a copyrighted work protected by copyright law.

Note that some of this standard may conflict with patent rights, post-publication patent applications or utility model rights. To arouse, The Minister of Economy, Trade and Industry and the Japanese Industrial Standards Committee have decided on such patent rights, patent applications after publication, and actual case. We are not responsible for confirmation of utility model rights.

(2)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Japanese Industrial Standards

JIS
A 1460 : 2021

Formaldehyde emission of building boards Test method-desiccator method

Determination of the emission of formaldehyde from building boards-
Desiccator method

1 Scope of application

This standard defines the amount of formaldehyde emitted from building boards (hereinafter referred to as boards).
The test method using a tar is specified.

Annex B shows the old and new comparison table for technically important revisions .

2 Citation standard

The following cited standards are partly or wholly required by this standard by being cited in this standard. Consists of. The latest versions (including supplements) of these cited standards apply.

JIS A 1902-1 Volatile organic compounds (VOC), formaldehyde and other carbonyl compounds released from building materials

Sampling, test piece preparation and test conditions for divergence measurement-Part 1: Boards, wallpaper and flooring

JIS K 0050 General rules for chemical analysis methods

Water used for **JIS K 0557** water / drainage test

JIS K 0970 Piston pipette

JIS K 8001 Reagent test method general rules

JIS K 8005 Standard material for volumetric analysis

JIS K 8027 Acetylacetone (reagent)

JIS K 8051 3-Methyl-1-butanol (reagent)

JIS K 8180 Hydrochloric acid (reagent)

JIS K 8355 acetic acid (reagent)

JIS K 8359 Ammonium acetate (reagent)

JIS K 8576 Sodium hydroxide (reagent)

JIS K 8625 Sodium carbonate (reagent)

JIS K 8637 Sodium thiosulfate pentahydrate (reagent)

JIS K 8659 Starch (Soluble) (Reagent)

JIS K 8872 Formaldehyde solution (reagent)

JIS K 8913 Potassium iodide (reagent)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18
Single user license only. Copying and networking prohibited. This is subject to the END USER LICENCE AGREEMENT.

2

A 1460: 2021

JIS K 8920 iodine (reagent)

JIS K 8951 Sulfuric acid (reagent)

JIS R 3503 Glassware for chemical analysis

JIS R 3505 glass volume meter

JIS Z 8401 How to round numbers

Standard condition of **JIS Z 8703** test site

ISO 13130 , Laboratory glassware-Desiccators

3 Terms and definitions

The main terms and definitions used in this standard are as follows.

3.1 3.1

Formaldehyde emission

Average of two sets of formaldehyde concentrations

3.2 3.2

Formaldehyde concentration

Concentration of formaldehyde absorbed in water by emission test

3.3 3.3

Boards

Rigid plate-shaped single material or composite product used as interior material

Note 1 For building material boards, **JIS A 5404** , **JIS A 5440** , **JIS A 5905** , **JIS A** are the material standards.

There are **5908** and **JIS A 6901** .

(Source: **JIS A 1902-1** : 2015 3.1)

Four Test principle

The test of the amount of formaldehyde emission from boards by the desiccator method is performed on the glass desiccator specified in Fig. 1 .

Perform using a sicator. Formaldehyde emission is the amount of water in the desiccator at a controlled temperature.

Formaldehyde, which was absorbed in water after 24 hours, was placed and a test piece of boards cut out to a predetermined surface area was installed.

Obtained from the concentration.

The principle of measuring the concentration of formaldehyde absorbed in water is that formaldehyde is ammonium ion and ace.

It reacts with tylacetone to produce diacetyldihydromorphine (DDL), which turns yellow (orange).

It is based on the Hantzsch reaction.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

a) When using the desiccator specified in **JIS R 3503**

b) When using the desiccator specified in **ISO 13130**

Symbol description

- 1: Desiccator
- 2: Specimen (see Fig. 2)
- 3: Stainless steel wire mesh
- 4: Glass crystal dish
- 5: Water
- 6: Glass plate

Figure 1 -Desiccator method device (configuration diagram)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Page 8

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18
Single user license only. Copying and networking prohibited. This is subject to the END USER LICENCE AGREEMENT.

Four

A 1460: 2021

a) Sketch

b) Floor plan

c) Side view

Symbol description

- 1: Test piece support hardware
- 2: Specimen

Figure 2- Mounting of test pieces (example)

Five General conditions

5.1 Test environment

The test location shall be at a temperature of $20^{\circ}\text{C} \pm 5^{\circ}\text{C}$ specified in **JIS Z 8703**.

5.2. Common conditions

The common conditions are as follows.

- a) General chemical analysis General items common to chemical analysis are in accordance with **JIS K 0050**.
- b) Water The water used in this standard shall be of A2 to A4 water specified in **JIS K 0557**, or of the same or higher quality.
Ion-exchanged water or distilled water.

6 Equipment and utensils

The equipment and appliances shall be as follows.

- a) Temperature / humidity measuring device The thermometer shall be able to measure the air temperature with an accuracy of 0.1°C . In addition, the hygrometer is a phase
It shall be possible to measure with an accuracy of 5% against humidity.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Five

A 1460: 2021

- b) Spectrophotometer** The spectrophotometer shall be capable of measuring the absorption wavelength in the range of 410 nm to 415 nm.
It is desirable to use an absorption cell with an optical path length of 50 mm or more.
- c) Constant temperature water tank** The constant temperature water tank used for analysis shall be able to maintain the temperature at $65^{\circ}\text{C} \pm 2^{\circ}\text{C}$.
- d) Chemical balances** Chemical balances can measure masses from 100 g to 200 g and can read a difference of 0.1 mg.
And
- e) Desiccator** The desiccator has a ball lid and is airtight, with a nominal size of 240 mm specified in **JIS R 3503**.
(**Name** in **JIS R 3503** : Desiccator 240 mm) or Type 2 specified in **ISO 13130** (Non-vacuum), those of series A, nominal diameter Mm 250 (**ISO 13130** nickname in: Desiccator **ISO 13130** -250-2A).
- f) Glass crystal dish** The glass crystal dish that holds water has an outer diameter of $120\text{ mm} \pm 5\text{ mm}$, an inner diameter of $115\text{ mm} \pm 1\text{ mm}$, and a depth of 60 mm.
It shall be $\pm 2\text{ mm}$.
It is desirable to have a spillage.
- g) Glass plate** The glass plate installed under the glass crystal dish shall be a circular one with a diameter of $120\text{ mm} \pm 5\text{ mm}$.
- h) Full volume flask** The full volume flask shall be specified in **JIS R 3505** .
- i) Full- volume pipette** Full- volume pipette specified in **JIS R 3505** (adjusted at 20°C), piston specified in **JIS K 0970**
A type pipette ¹⁾ or an automatic pipette with an accuracy equal to or higher than these.
Note ¹⁾ Also called a micropipette on the market.
- j) Burette** A burette specified in **JIS R 3505** or an automatic weighing device with an accuracy equal to or higher than this ²⁾ .
NS.
Note ²⁾ It is supplied to the market as an automatic titrator.
- k) Flask with stopper** The flask with stopper shall be a common ground-glass Erlenmeyer flask specified in **JIS R 3503** .
- l) Specimen support hardware** The test piece support hardware for fixing the test piece in the desiccator shall be made of stainless steel.
- m) Stainless steel wire mesh** The wire mesh on which the test piece support hardware with the test piece attached is placed in the desiccator is stainless steel.
The mesh spacing of the wire parts shall be 230 mm to 240 mm with a diameter larger than 15 mm.
- n) Graduated cylinder** The graduated cylinder shall be a graduated cylinder specified in **JIS R 3505** .

7 Preparation of reagents

Preparation of reagents is as follows.

The reagents specified in **a)** to **f)** and **h)** may be prepared by changing the total amount of reagents without changing the concentration of the reagents.

- a) 0.05 mol / L iodine solution** Prepare the 0.05 mol / L iodine solution by any of the following. However, this solution is
Place in a light-shielded airtight container and store in a dark place.
- 1)** Dissolve 40 g of potassium **iodide** in 25 mL of water as specified in **JIS K 8913**, and specify it in **JIS K 8920** .
After dissolving 13 g of **urine** , transfer it to a total volume flask of 1 000 mL, and use hydrochloric acid specified in **JIS K 8180** (special).
Class) After adding 3 drops, add water up to the marked line and mix.
- 2) JIS K 8001 of JA.6.4 w)** (0.05 mol / L so volumetrically for 0.05 mol / L so was prepared by iodine solution) Moto溶
Liquid ³⁾ .
Note ³⁾ It is supplied to the market as an iodine solution of 0.05 mol / L for volumetric analysis.
- b) 0.1 mol / L sodium thiosulfate solution** Preparation of 0.1 mol / L sodium thiosulfate solution should be done by any of the following.
NS.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

6

A 1460: 2021

- 1)** 26 g of sodium thiosulfate pentahydrate specified in **JIS K 8637** and charcoal specified in **JIS K 8625** as a preservative
Dissolve 0.2 g of sodium acid in 1 000 mL of dissolved oxygen-free water, leave it for 2 days, and then add it to **JIS K 8005** .
JIS K 8001 JA.6.4 t) 2) (0.1 mol / L sodium thiosulfate solution) using potassium **phosphate** as **specified**.
The solution calibrated by.

As the preservative, use an appropriate amount of 3-methyl-1-butanol specified in **JIS K 8051**, or use it.
May be used in combination with sodium carbonate.

- 2) **JIS K 8001** of **JA.6.4 t** 2 the capacity for analysis 0.1 was prepared by) mol / L sodium thiosulfate solution or 0.1
A volumetric sodium thiosulfate solution with a concentration higher than mol / L was prepared using a volumetric pipette and volumetric flask.
In solution accurately diluted Te, **JIS K 8005** by using a potassium iodate as specified in, **JIS K 8001** of **JA.6.4**
t) The standardization according to 2).
- 3) A 0.1 mol / L sodium thiosulfate solution for volumetric analysis as a certified reference material 4) whose concentration has been calibrated.
of.

Note 4) As a supplier of certified reference materials, National Institute of Advanced Industrial Science and Technology, Metrology Standards General Center
National metrology institutes such as the Inter (NMIJ) and the National Institute of Standards and Technology (NIST) and certified reference materials.
There is a producer.

- c) **1 mol / L** sodium hydroxide solution The preparation of 1 mol / L sodium hydroxide solution shall be as follows.
- 1) Dissolve 40 g of sodium hydroxide specified in **JIS K 8576** in 200 mL of water, and add this to a total volume flask of 1 000 mL.
A solution in which water was added up to the marked line and mixed.
- 2) **JIS K 8001** of **JA.6.4 r** 1) (1 mol / L aqueous capacitance analysis was prepared by 1 mol / L sodium hydroxide solution)
Sodium oxide solution.
- d) Sulfuric acid (**1 mol / L**) Dissolve 56 mL of sulfuric acid specified in **JIS K 8951** in 200 mL of water, and add this to a total volume flask 1 000.
Transfer to mL, add water up to the marked line and mix.
- e) Starch solution Mix 1 g of starch (soluble) specified in **JIS K 8659** with 10 mL of water and in 200 mL of hot water.
Add while stirring. A solution that has been boiled and cooled for about 1 minute.
- f) Formaldehyde standard stock solution 1 mL of formaldehyde solution specified in **JIS K 8872** is put in a full volume flask 1 000
A solution that was placed in mL, water was added up to the marked line, and the mixture was mixed.
The formaldehyde concentration of this standard stock solution is as follows.
Add 20 mL of the prepared standard formaldehyde stock solution to 100 mL of a flask with a stopper using a pipette.
Take exactly 25 mL of 0.05 mol / L iodine solution, add 10 mL of 1 mol / L sodium hydroxide solution, and shield from light.
Leave it at room temperature for 15 minutes. In addition, add 15 mL of sulfuric acid (1 mol / L) to immediately remove the liberated iodine.
Titrate with a burette in 0.1 mol / L sodium thiosulfate solution. After the solution turns pale yellow,
Add 1 mL of Pun solution as an indicator. Add starch solution to make a bluish or reddish bluish-black solution.
Titration is completed when the solution becomes colorless and transparent, and the titration of 0.1 mol / L sodium thiosulfate solution is determined. another
A blank test was performed using 20 mL of water, and the formaldehyde concentration in the formaldehyde standard stock solution was determined by the formula (1).
Calculate the degree.

$$C = 1.5 \times (V_0 - V) \times f \times (1\,000/20) \dots\dots\dots$$

here, C : Formaldehyde concentration in formaldehyde standard stock solution
(Mg / L)
1.5: Holm equivalent to 1 mL of 0.1 mol / L sodium thiosulfate solution
Aldehyde amount (mg / mL)
V₀ : Titration of 0.1 mol / L sodium thiosulfate solution in blank test
(ML)
V : 0.1 mol / L sodium thiosulfate in formaldehyde standard stock solution
Titration of solution (mL)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

f : Factor of 0.1 mol / L sodium thiosulfate solution
20: Volume of the titrated formaldehyde standard stock solution (mL)

- g) Formaldehyde standard solution The formaldehyde standard solution shall be prepared by one of the following.
- 1) Put the standard formaldehyde stock solution in a volumetric flask so that 1 000 mL of water contains 3 mg of formaldehyde.
A solution in which an appropriate amount was taken in 1 000 mL, water was added up to the marked line, and the mixture was mixed.
- 2) Holmarde, traceable to national metrology standards, provided by the Metrology Standards Supply System (JCSS)
Take 1.5 mL of Hido standard solution (HCHO for water quality test: 1 000 mg / L) as a stock solution in a 500 mL volumetric flask.
A solution in which water is added up to the marked line and mixed.
- h) Acetylacetone-ammonium acetate solution 150 g of ammonium acetate specified in **JIS K 8359** in water 800
Dissolve in mL, and add 3 mL of glacial acetic acid specified in **JIS K 8355** and acetylacetone specified in **JIS K 8027**.
Add 2 mL, mix well, and add water to make 1 L. If you cannot measure immediately,
It may be stored in a cool and dark place at 0 ° C to 10 ° C for no more than 3 days after preparation. However, if stored, the test location

Return to temperature and use.

8 Test pieces

8.1 8.1 Cutting out test pieces

When cutting out the test piece, avoid the edges of the boards selected by a rational sampling inspection method. Consider the requirements necessary for inspecting the characteristics of boards.

Regarding the cutting out of test pieces, **JIS A 1902-1** Clause 4 (sample collection, packaging and storage) and Clause 5 (Preparation of test piece).

8.2 8.2 Dimension and number of test pieces

The dimensions and number of test pieces shall be as follows.

- a) The dimensions of the test piece shall be 150 mm \pm 1 mm in length and 50 mm \pm 1 mm in width.
- b) The number of test pieces shall be such that the total area of the front and back surfaces is closest to 1 800 cm². Two sets of this To make.

8.3 Curing

Curing is as follows.

- a) The test piece becomes constant in the standard state of temperature 20 °C \pm 2 °C and relative humidity (65 \pm 5)% specified in **JIS Z 8703**.
Cure up to. This constant amount is the difference in mass between the test pieces before and after the mass measurement performed every 24 hours. When it reaches 0.1% or less.
One week after the start of curing may be regarded as a constant dose.
- b) Each test piece shall be at least 25 mm from each other so that air can freely contact the entire surface under the standard conditions specified in a).
Must be separated. In addition, the test piece with a small amount of formaldehyde emission is the formaldehyde of the surrounding environment. Since it may absorb dehydration, it is necessary to pay attention to the environment during curing.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

8

A 1460: 2021

9 Test method

9.1 Preparing for the exam

Preparation for the test is as follows.

- a) Prepare multiple desiccators and glass crystal dishes (usually 3 each) and glass plates as needed.
Then, wash each of them thoroughly with water and dry them before the test.
- b) The desiccator was adjusted so that its internal temperature was 20 °C \pm 0.5 °C specified in **JIS Z 8703**.
Stand still in place (see **9.3.1**).
- c) Put 300 mL \pm 1.5 mL of water in 3 glass crystal dishes with a measuring cylinder, and b) of the desiccator.
Install in the center of the bottom.
ISO 13130 when using desiccator specified in the FIG. **1 b** as), the position of the glass crystallizing dish
Place a glass plate in the center of the bottom of the desiccator so that it is raised 25 mm \pm 2 mm from the bottom of the desiccator.
Install.
It should be noted that a plurality of glass plates may be stacked and raised.
- d) Place the stainless steel wire mesh on the glass crystal dish in the desiccator as shown in Fig. **1** .
- e) Attach the prescribed number of cured test pieces to the test piece support hardware as shown in Fig. **2** . Prepare two sets of this.

9.2 Start of emission test

The start of the emission test is as follows.

- a) Place the mounted test piece on a stainless steel wire mesh in a desiccator. Prepare two sets of this.

The other desiccator is used for background formaldehyde concentration measurement, and is a test piece.

Do not wear.

b) Cover the desiccator and start the emission test.

9.3 Condition monitoring of test conditions

9.3.1 temperature

Using a desiccator without a test piece, the temperature inside the desiccator should not exceed continuous or 15 minutes.

Measure at intervals and record the temperature during the test. For the temperature, use a thermocouple in the test environment near the desiccator.

It may be attached and measured.

9.3.2 Background formaldehyde concentration measurement (blank test)

The background formaldehyde concentration is measured using a desiccator without a test piece.

The background formaldehyde concentration should not exceed 0.05 mg / L.

9.4 test time

The time required for one emission test shall be 24 hours \pm 10 minutes.

9.5 Collection of test solution

The water in the glass crystal dish after the emission test is used as the test solution. After the emission test, a glass crystal dish containing the test solution

Remove from the desiccator and mix well with the test solution. 100 mL of flask with a stopper is the solution for this test.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

After cleaning with, fill with this test solution and plug with glass. Directly check the formaldehyde concentration in the test solution

If it cannot be measured later, it may be stored at 0 ° C to 5 ° C for up to 30 hours. If stored, return to test site temperature

And use.

9.6 Measurement of formaldehyde concentration in test solution

The formaldehyde concentration in the test solution is measured by the acetylacetone absorptiometry.

Accurately place 5 to 25 mL of the test solution in a flask with a stopper, then the same amount of acetylacetone-vinegar.

Add ammonium acid solution, lightly plug and mix so that the solution does not leak when mixing. This frass with a stopper

After heating for 10 minutes in a constant temperature water bath at 65 ° C \pm 2 ° C, the solution was shielded from light until it reached the temperature of the test site.

Let it stand still. Take this solution in an absorption cell and measure the absorbance at a wavelength of 412 nm with a spectrophotometer using water as a control.

NS. If maximum absorption occurs at wavelengths other than 412 nm, maximum absorption occurs for all measurements, including the creation of calibration curves.

It may be measured at the wavelength to be measured.

If the formaldehyde concentration in the test solution exceeds the range of the calibration curve, the test solution is appropriately diluted.

The formaldehyde concentration in the diluted solution may be determined by measuring the solution according to 9.6 .

Similarly, in the test solution in the desiccator crystal dish prepared for background formaldehyde measurement.

Also measure.

9.7 Creating a calibration curve

Take 0 mL, 5 mL, 10 mL, 20 mL, 50 mL and 100 mL of formaldehyde standard solution with a pipette.

After putting them in separate 100 mL volumetric flasks, add water up to the marked line to make a formaldehyde solution for preparing a calibration curve.

For the calibration curve, accurately separate 5 mL to 25 mL from each formaldehyde solution for preparing the calibration curve, and operate in 9.6 .

And prepare from the relationship line between formaldehyde concentration (0 mg / L to 3 mg / L) and absorbance. Relationship line at that time

The slope (*F*) of is obtained by graph or calculation.

Even if the concentration range of the formaldehyde solution for preparing a calibration curve is narrowed according to the expected concentration of the test solution.

good. However, in the range including the formaldehyde concentration in the test solution, the formaldehyde concentration is other than 0 mg / L.

Set the concentration level of the formaldehyde solution for preparing a calibration curve in 5 stages.

Create a calibration curve at least once a month.

9.8 Calculation

The formaldehyde concentration in the test solution in the desiccator containing the test piece is calculated by Eq. (2).

$$G = F \times (A_d - A_b) \times 1800 / A$$

here, G : Holmua in the test solution in the desiccator containing the test piece
Rudehide concentration (mg / L)

F : Slope of relational line for formaldehyde standard solution
(Mg / L)

A_d : absorbance of test solution in a desiccator over specimen

A_b : Absorbance of the test solution in the background desiccator

1800: Total area of the edge surface and front and back surfaces of the test piece specified in **8.2**
(Cm²)

A : Surface area of test piece (cm²)

Formaldehyde concentration is calculated for each of the two sets of test pieces, and is after the decimal point according to Rule B of **JIS Z 8401**.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Page 14

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18
Single user license only. Copying and networking prohibited. This is subject to the END USER LINCENCE AGREEMENT.

Ten

A 1460: 2021

Round to one digit. However, the difference in formaldehyde concentration between the two sets is 0.2 mg / L or more, and the test results of the two sets are the same.

If there is a difference of 20% or more from the average value of, prepare two sets of new test pieces and test according to Clause **8** and Clause **9**.

Repeat the test.

9.9 Display of test results

The formaldehyde emission amount, which is the test result, is shown by calculating the average of the two sets of measured formaldehyde concentrations.
Show.

10 reports

The test report shall include the following (see Annex A).

- a) Specimen type and its dimensions (mm)
 - b) Number of test pieces
 - c) Type of desiccator (for example, desiccator specified in **JIS R 3503**)
 - d) Formaldehyde emission amount (average value of formaldehyde concentration obtained in **9.9**), formaldehyde in each measurement
Concentration (including background values)
 - e) Test date
 - f) Temperature inside the desiccator during the emission test (see **9.3.1**)
 - g) Testing institution name
 - h) Name of person in charge of testing
- The following items shall be stated in the test report as necessary.
- i) Specimen density (kg / m³)
 - j) Cutout position of the test piece (for example, the cutout position from the board is shown)
 - k) Producer's name, place of manufacture, date of manufacture or lot number
 - l) Preservation conditions of materials from manufacturing to sampling inspection, especially matters related to formaldehyde emission in the air, do not
Wow, temperature, humidity, material sealing status, storage status, etc.
 - m) Sampling inspection method and sampling date
 - n) Location where the test piece was removed from the factory or building ^{s)} and condition ^{e)} (For example, shown in an image such as a photograph)
 - o) Location where test pieces from buildings, furniture, etc. were collected ^{s)} and condition ^{e)} (For example, shown in images such as photographs)
 - p) Temperature, humidity and time of the cured state of the test piece
 - q) In addition, if this test method is not used, all items related to the test (preparation, temperature, etc.)

Note ^{s)} For example, in the case of factories, or in the case of constructed boards, ceilings, floors, walls, etc.

Note ^{e)} For example, moisture content, surface coating, finishing, etc.

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18
Single user license only. Copying and networking prohibited. This is subject to the END USER LICENCE AGREEMENT.

11 11

A 1460: 2021

Annex A
(reference)
Example of test report

Test name	Performance test of cosmetic MDF				
Requester	○○○○ Co., Ltd.				
Test items	Formaldehyde emission				
Test pieces	Name: Makeup MDF				
	Material: Decorative sheet, MDF				
	Dimensions: 50 mm x 150 mm x 12 mm				
	Quantity: 18 pieces (9 pieces x 2 sets)				
Test method	According to JIS A 1460 (Test method for formaldehyde emission of building boards-desiccator method)				
	I went.				
	Desiccator type: Nominal size 240 mm specified in JIS R 3503 Desiccator temperature: 20.1 ° C				
Test results	Test pieces	Analysis result mg / L			Lower limit of quantification
	number	De with a test piece	Formaldehyde	For background	
		Trial in the sicator	De-emission amount	Trial in desiccator	
		Hol in test solution		Holm in test solution	
		Maldehyde concentration		Aldehyde concentration	
	1	0.2 0.2	0.3	<0.02	0.02
	2	0.3			
Test date	○○○○ year ○○ month ○○ day ~ ○○ month ○○ day				
Test performer	○○○○				
Testing institution	○○○○ Co., Ltd. (○○ prefecture ○○ city ○○ town ○○-○○-○)				

References

- JIS A 5404 Wood-based cement board
- JIS A 5440 Volcanic vitreous multi-layer board (VS board)
- JIS A 5905 fiber board
- JIS A 5908 particle board
- JIS A 6901 gypsum board product
- ISO 12460-4 : 2016, Wood-based panels-Determination of formaldehyde release-Part 4: Desiccator method

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

Annex B
(reference)

Old and new comparison table for technically important revisions

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number And title	Contents	Clause number And title	Contents	
Copyright law	3 terms and Definition	Formaldehyde emission amount, formaldehyde concentration and Define boards	-	-	Formaldehyde emission and formaldehyde Clarify the relationship with aldehyde concent Added definition of terms for. Also, JIS A as a source for the definition of boards 1902-1 is described.
By					
Nothing Duplex by decisive	4 Test source Li	JIS R 3503 desiccator and specified in ISO 13130 to Configuration diagram of the desiccator method to be specified	3 Test source Li	Of the desiccator method specified in JIS R 3503 Diagram	In the block diagram of the desiccator method Added desiccator specified in 13130 bottom.
Made, rolled					
Listed Etc. are prohibited		Formaldehyde is ammonium ion and acetyl Diacetyldihydrormorphine by reacting with acetone A haunch that generates (DDL) and finally turns (orange) yellow (Hantzsch) Based on reaction.		Formaldehyde is ammonium ion And react with acetylacetone, Diacetyldihydrormorphine (DDL) is raw Based on the Hantzsch reaction that occurs There is.	Contains formaldehyde by absorptimetry Since it measures a large amount, it is close to Added the coloration of.
Being done					
Oh I will.	5.1 Test ring Border	The test location is the temperature specified in JIS Z 8703 , 20 ° C ± 5 ° C. It is in the state of.	4.1 Test ring Border	The test location is 20 ° C specified in JIS Z 8703 . The temperature shall be in the 0.5 class (20 ± 0.5 ° C).	Temperature during curing and emission test o Applicable to Clause 8 and Clause 9 It is specified in the place. Here, the other procedure (absorbance) About the test location where the measurement ± 0.5 ° C is excessive It was a request. Analytical equipment etc. ear Sufficient temperature range to work Changed to ± 5 ° C.
	5.2 Common conditions b) Water	The water used in this standard is A2 ~ specified in JIS K 0557 . A4 water or ion exchange with quality equal to or better than them Use water exchange or distilled water.	4.2 Common conditions b) Water	The water used in this standard is specified in JIS K 0557 . Constant to A1 ~ A4 water, or JIS K 0557 of Ion exchange with the same quality as A1 to A4 Water or distilled water.	A1 water specified in JIS K 0557 is a contain Since it is used for cleaning ingredients, it will The quality was A2 or higher.

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number And title	Contents	Clause number And title	Contents	
Copyright law	6 equipment and Equipment e) Desike -Ter	The desiccator has a ball lid and is airtight JIS R Nominal dimension 240 mm specified in 3503 (JIS R 3503) Name in : Desiccator 240 mm), or ISO 13130 Type 2 (Non-vacuum), Series A, Nominal With a diameter of 250 mm (name in ISO 13130 : Desiccator) ISO 13130-250-2A).	5 equipment and Equipment e) Desike -Ter	The desiccator is JIS R 3503 with airtightness. Nominal dimension of 240 mm specified in NS.	As defined in the old standard " JIS R 3503 s Desiccator with a nominal size of 240 mm -Since the production of "-" has ended, it will And ISO 13130 desiccator as defined in Added a tar.
By					
Nothing Duplex by decisive	6 equipment and Equipment g) glass Board	The glass plate installed under the glass crystal dish has a diameter of 120 mm. It shall be a circle of ± 5 mm.	-	-	Used to raise the glass crystal dish Added the regulation of the glass plate to be u The glass plate is specified in ISO 13130 . If you select a desiccator to do It is to be used.
Made, rolled					
Listed Etc. are prohibited	6 equipment and Equipment i) Total amount Pets	Full volume flasks shall be specified in JIS R 3505 . 5 equipment and h) Total amount Rasco Full- volume pipette specified in JIS R 3505 (adjusted at 20 ° C), Piston type pipette specified in JIS K 0970) or this An automatic pipette with an accuracy equal to or higher than these. Note 1) Also called a micropipette on the market.	5 equipment and Equipment g) Total amount Rasco 5 equipment and Equipment h) Total amount Pets	Total volume flasks are referred to as specified in JIS R 3505 . And the capacity is 100 mL and 1 000 mL. NS. The total pipette is the nominal value specified in JIS R 3505 . And capacity 5 mL, 10 mL, 15 mL, 20 mL, 25 mL, 50 mL, 100 mL total volume pipette (20 ° C) Adjusted by) or self with equivalent quality Use a dynamic pipette.	The capacity of the volumetric flask is the liq It should be selected according to the capacity Therefore, the capacity regulation has been de The volume of the total pipette is the liquid us It should be selected according to the capacity Therefore, the capacity regulation has been de A formula pipette was added as an option.
Being done					
Oh I will.	6 equipment and	Flasks with stoppers are common grinds specified in JIS R 3503 .	5 equipment and	Flasks with stoppers are specified in JIS R 3503 .	The capacity of the flask with a stopper is use

Equipment	Make a combined Erlenmeyer flask.	Equipment	Common ground joint triangle with a nominal capacity of 108 mL according to the volume of liquid
k) With stopper		j) With stopper	Make a flask.
Flask		Flask	
6 equipment and	Test piece support hardware with test piece attached in a desiccator	5 equipment and	A test with a test piece attached in a desiccator
Equipment	The wire mesh on which the wire mesh is placed is the distance between the mesh of the stainless steel wire mesh	Equipment	The distance between the mesh of the stainless steel wire mesh which the specimen support hardware is placed in a desiccator
m) Stainless	Made larger than 15 mm in diameter from 230 mm to 240 mm	l) Stainless	The mesh spacing of the wire part is from 15 mm
Less wire mesh	It shall be.	Less wire mesh	Larger diameter 240 mm

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number	Contents	Clause number	Contents	
	6 equipment and	The graduated cylinder is a graduated cylinder specified in JIS R 3505 .	-	-	Graduated cylinder to measure the volume of Added a dar.
	Equipment	Let's call it Dar.			
	n) Messi				
	Linder				
	7 Reagent adjustment	Preparation of reagents is as follows.	-	Preparation of reagents is as follows.	As specified in a) to f) and h)
	Made	The reagents specified in a) to f) and h) use the reagent concentration.			When preparing reagents in, most of the reagent
Copyright law		The total amount of the reagent may be changed without changing the preparation.			It will be necessary to treat it as waste liquid. Reagents considering the environmental impact
By	7 Reagent adjustment	The preparation of the 0.05 mol / L iodine solution shall be as follows.	6 Reagent adjustment	potassium iodide 40 as specified in JIS K 8913	According to the old standard, 0.05 mol / L iodine
Nothing Duplex by decisive	Made	However, put this solution in a light-shielded airtight container in a dark place.	Made	Dissolve g in 25 mL of water and add JIS K 8920 to this.	It only specified to prepare,
	a) 0.05	Save to.	a) Iodine	After melting 13 g of iodine as specified in	In the current standard, it is a solution for volumetric
	mol / L	1) Add 40 g of potassium iodide to water 25 as specified in JIS K 8913 .	Solution (0.05	Transfer this to a 1 000 mL flask, and put it in a bottle.	Reagents commercially available as liquids and
Made, rolled	Elementary solution	Dissolve in mL and specify in JIS K 8920 .	mol / L)	Added 3 drops of hydrochloric acid specified in JIS K 8180	Added so that it can be done.
Listed Etc. are prohibited		After melting 13 g of the element, put it in a full volume flask 1 000		After that, a solution prepared by adding water up to the marked line.	
Being done		Transfer to mL and specify hydrochloric acid specified in JIS K 8180 (special Class) After adding 3 drops, water was added up to the marked line and mixed.			
Oh I will.		solution.			
		2) JIS K 8001 of JA.6.4 w) (0.05 mol / L iodine solution)			
		0.05 mol / L iodine solution for volumetric analysis prepared by			
		Liquid 3) .			
		Note 3) City as 0.05 mol / L iodine solution for volumetric analysis			
		It is being supplied to the field.			

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number	Contents	Clause number	Contents	
	7 Reagent adjustment	Preparation of 0.1 mol / L sodium thiosulfate solution is as follows.	6 Reagent adjustment	Sodium thiosulfate specified in JIS K 8637	In the old standard, sodium thiosulfate solution
	Made	It depends on that.	Made	Specified in 26 g of pentahydrate and JIS K 8625	Sodium thiosulfate pentahydrate and charcoal
	b) 0.1 mol / L	1) Sodium thiosulfate pentahydrate specified in JIS K 8637	b) Thio-sulfur	Contains 0.2 g of dissolved oxygen	Prepare by mixing with sodium acid
	Thiosulfate	26 g of charcoal and charcoal specified in JIS K 8625 as a preservative	Acid Natriu	Dissolve in 1 000 mL of no water and leave for 2 days	It was only specified that, but the current standard
	Thorium melting	0.2 g of sodium acid and dissolved oxygen-free water	Solution (0.1	After that, as specified in JIS K 8005	Then, if you add the choice of preservatives

liquid Dissolve in 1 000 mL, leave for 2 days, then **JIS K 8005** mol / L) Using a **lithium** , **JIS K 8001 JA.6.4 t) 2)** Both are thiosulfate natri for volumetric analy:
 Using potassium iodine as specified in **JIS K 8001** The solution calibrated by. Umm solution (commercially available) or its
 Copyright law Of **JA.6.4 t) 2)** (0.1 mol / L sodium thiosulfate solution) Solutions and certified reference materials can
 The solution calibrated by. Added as.
 By Preservatives are specified in an appropriate amount of **JIS K 8051** .
 Nothing Duplex by decisive Use 3-methyl-1-butanol or use it
 Made, rolled May be used in combination with sodium carbonate.
 Listed Etc. are prohibited **2) JIS K 8001 of JA.6.4 t) 2** volume fraction was prepared by)
 Being done 0.1 mol / L sodium thiosulfate solution for analysis or 0.1
 Oh I will. Natriu thiosulfate for volumetric analysis at higher concentrations than mol / L
 Using a total volume pipette and a total volume flask
 Accurately diluted solution, specified in **JIS K 8005**
 Yo with potassium iodate, **JIS K 8001 of JA.6.4**
t) The standardization according to **2)** .
3) 0.1 mol / L thio for volumetric analysis as certified reference material **4)**
 The concentration was calibrated with sodium sulfate solution.
 of.
 Note **4)** National as a supplier of certified reference materials
 National Institute of Advanced Industrial Science and Technology, Research and Development Agency
 Semi-Comprehensive Center (NMIJ), US National Standard Technology
 National Institute of Standards and Measures (NIST) and
 There are certified reference material producers.

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number	Contents	Clause number	Contents	
	And title		And title		
	7 Reagent adjustment	Preparation of 1 mol / L sodium hydroxide solution is one of the following:	6 Reagent adjustment	Sodium hydroxide specified in JIS K 8576	The old standard uses sodium hydroxide
	Made	according to.	Made	Dissolve 40 g in 200 mL of water and add the whole amount.	Was only specified to be prepared
	c) 1 mol / L	1) Add 40 g of sodium hydroxide specified in JIS K 8576 to water.	c) Hydroxide	Transfer to 1 000 mL of Lasco and mark with water.	However, in the current standard, hydroxide fi
	Nato hydroxide	Dissolve in 200 mL and add to a 1 000 mL volumetric flask.	sodium	The solution prepared by adding in.	Commercially available as a sodium chemical
	Rium solution	Transfer, add water up to the marked line and mix.	Solution (1		Add the existing reagents so that they can be u
		2) JIS K 8001 of JA.6.4 r) 1) (1 mol / L hydroxide sodium	mol / L)		rice field.
Copyright law		1 mol / L water for volumetric analysis prepared by			
		Sodium oxide solution.			
	7 Reagent adjustment	After the solution turns pale yellow, finger 1 mL of starch solution.	6 Reagent adjustment	After the solution turns pale yellow, starch is dissolved.	In the old standard, after adding starch solution
By	Made	Add as an indication. Add starch solution, blue or red	Made	Add 1 mL of liquid as an indicator and further titrate.	Because the titration procedure was omitted
Nothing Duplex by decisive	f) Holm	When the bluish-black solution becomes colorless and transparent	f) Holm	NS.	Clarified.
	aldehyde	Titration is completed with 0.1 mol / L sodium thiosulfate solution.	aldehyde		
	Standard stock solution	Obtain titration.	Standard stock solution		
	7 Reagent adjustment	Preparation of formaldehyde standard solution should be one of the following:	6 Reagent adjustment	Formaldehyde standard stock solution 1 000 mL of water	In the old standard, formaldehyde standard so
Made, rolled	Made	evening.	Made	To contain 3 mg of formaldehyde in	Only regulates and titrates the liquid
Listed Etc. are prohibited	g) Holm	1) Formaldehyde standard stock solution in 1 000 mL of water	g) Holm	In addition, take an appropriate amount in a total volume flask	Now in the current standard, JCSS certifi
	aldehyde	Total volume flask to contain 3 mg of mualdehyde	aldehyde	A solution prepared by adding water up to the marked line.	Formaldehyde standard solution with a statem
Being done	Standard solution	Take an appropriate amount in 1 000 mL, add water up to the marked line	Standard solution		The diluted solution is also formaldehyde
Oh I will.		Solution.			Added so that it can be used as a standard solu
		2) Provided by the Metrology Standards Supply System (JCSS),			Added.
		Holmarde, traceable to national metrology standards			
		Hido standard solution (HCHO for water quality test: 1 000 mg / L) 1.5			
		Using mL as the undiluted solution, take a total volume of 500 mL into a flask.			
		A solution in which water is added up to the marked line and mixed.			

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number	Contents	Clause number	Contents	
	9.1 of the exam	Preparation for the test is as follows.	8.1 Test equipment	Preparation of the test equipment shall be as follows.	To prepare (clean and dry) equipment
	Preparation	<p>a) Multiple desiccators and glass crystal dishes (usually 3 each) and glass plate as needed</p> <p>Therefore, wash each of them thoroughly with water and dry them before the test.</p> <p>NS.</p> <p>b) The internal temperature of the desiccator is specified in JIS Z 8703 .</p> <p>Adjusted to a fixed temperature of 20 ° C ± 0.5 ° C</p> <p>Let it stand still (see 9.3.1) .</p> <p>c) 300 mL ± with a graduated cylinder in 3 glass crystal dishes</p> <p>Add 1.5 mL of water and b) desiccator.</p> <p>Install in the center of the bottom of the.</p> <p>Use the desiccator specified in ISO 13130</p> <p>In this case, the position of the glass crystal dish as shown in Fig. 1b) .</p> <p>Raise 25 mm ± 2 mm from the bottom of the desiccator</p> <p>Glass in the center of the bottom of the desiccator</p> <p>Install the board.</p> <p>It should be noted that multiple glass plates are stacked and used on top of each other.</p> <p>You may get rid of it.</p> <p>d) As shown in Fig. 1 , the glass crystal dish in the desiccator</p> <p>Place a stainless steel wire mesh on top.</p> <p>e) As shown in Fig. 2 , a predetermined number of cured test pieces are shown</p> <p>Attach to the test piece support hardware. Prepare two sets of this.</p>	<p>Preparation for place</p> <p>a) Multiple desiccators and glass crystal dishes</p> <p>Prepare several (usually 3) and try each one.</p> <p>Thoroughly wash with water and dry before the test.</p> <p>d) Multiple desiccators have their internal temperature</p> <p>Is adjusted to 20 ± 0.5 ° C</p> <p>Place it in the test site.</p> <p>b) Add 300 ± 1 mL of water to each glass crystal dish.</p> <p>Put in, the center of the bottom of the desiccator</p> <p>Install in.</p> <p>c) As shown in Fig. 1 , the glass in the desiccator</p> <p>Place a stainless steel wire mesh on the crystal dish.</p> <p>Place the test piece support hardware on it Fig. 2</p> <p>Place as shown in.</p> <p>a) A predetermined number of cured test pieces, test pieces</p> <p>Installation of charges</p> <p>Attach it to the support hardware.</p>	<p>Added a board.</p> <p>Change the test procedure according to the act rice field.</p> <p>The desiccator is placed in a glass crystal dish</p> <p>It was the procedure before installation.</p> <p>Measure the volume of water with a graduated</p> <p>In addition, the capacity tolerance is JIS R</p> <p>According to Class A specified in 3505 .</p> <p>Follow the procedure for installing the glass pi</p> <p>Added.</p> <p>Test piece specified in 8.2 a) of the old standa</p> <p>The procedure for attaching the test piece to th</p> <p>Moved to 9.1 .</p>	
Copyright law					
By					
Nothing Duplex by decisive					
Made, rolled					
Listed Etc. are prohibited					
Being done					
Oh I will.					
	9.2 Dissipation test	The start of the emission test is as follows.		The measurement sample is attached as follows.	In the old standard, the procedure for mountin
	Start of trial	<p>a) The attached test piece is made of stainless steel in the desiccator.</p> <p>Place it on the wire mesh. Prepare two sets of this.</p> <p>The other desiccator is the back glass.</p> <p>Tested for measuring the formaldehyde concentration of the und</p> <p>Do not attach a piece.</p> <p>b) Cover the desiccator and start the emission test.</p>	<p>a) A predetermined number of cured test pieces, test pieces</p> <p>Attach it to the support hardware.</p> <p>For one desiccator, try</p> <p>Do not attach the test piece.</p> <p>b) Cover the desiccator and perform a emission test.</p> <p>Start.</p>	<p>Because it was done, it was changed according</p> <p>rice field. Along with that, the title of the clau</p> <p>Changed to "Start test".</p>	

	Current standard (JIS A 1460 : 2021)		Old standard (JIS A 1460 : 2015)		Reason for revision
	Clause number	Contents	Clause number	Contents	
	9.4 During the test	The time required for one emission test is 24 hours ± 10 minutes.	8.4 At the time of test	The time required for one emission test is 24 hours.	Affects formaldehyde concentration measuren
	while	NS.	while	± 5 minutes.	Tolerable range of test time without giving
	9.6 For testing	Accurately place 5 mL to 25 mL of test solution in a flask with a stopper	8.6 For testing	Formaldehyde in solution for quantitative operation test	From the viewpoint of reducing waste liquid, t
	E in solution	Add, then the same amount of acetylacetone-acetate	E in solution	Acetylacetone absorptiometry	Measure the amount (25 mL) with a spectroph
	Lumuarde	Add a mneumonion solution and prevent the liquid from leaking when mixing.	Lumuarde	Measured by.	5 so that it can be reduced to a certain extent
	Hidden concentration	Lightly plug and mix. This flask with a stopper	Hidden concentration	25 mL of the test solution shown in 8.5	It was changed to mL to 25 mL.
Copyright law	Samadhi	After heating for 10 minutes in a constant temperature water bath at 65 ° C ± 25	Samadhi	Place in Erlenmeyer flask, then acetyl	
By		Let the solution stand in the dark until it reaches the temperature of the test site.		25 mL of acetone-ammonium acetate solution	"Room temperature" as "test site temperature"
Nothing Duplex by decisive		do. Take this solution in an absorption cell and use water as a control.		Add, lightly plug and mix. This common	Specifically described.
Made, rolled		Measure the absorbance at a wavelength of 412 nm with a spectrophotometer. 412 nm		Place the ground-glass Erlenmeyer flask at 65 ± 2 ° C.	
Listed Etc. are prohibited		If maximum absorption occurs at wavelengths other than the above, create a calibration curve.		After warming in water for 10 minutes, put this solution in the	The contents of the notes have been organized
Being done		All measurements, including formation, are measured at the wavelength at which maximum absorption occurs.		Put in a shaded state until it becomes warm.	
		You may decide.		Take this solution in an absorption cell and use water as a control.	
		In addition, the formaldehyde concentration in the test solution is the calibration curve.		Then, at a wavelength of 412 nm, the absorbance with a spectrophotometer	
		If the above range is exceeded, use a test solution diluted appropriately.		To measure.	
		Holm in diluent by measuring according to 9.6		Similarly, the background holm	
		The aldehyde concentration may be determined.		Also measure aldehydes. 412 nm	

Oh I will.

Similarly for background formaldehyde measurements About the test solution in the prepared desiccator crystal dish Even measure.

When maximum absorption occurs at wavelengths other than Is this for all measurements, including calibration curve creation It may be measured by wavelength.

NOTE Formaldehyde in test solution

- De-concentration exceeded the range of the calibration curve In some cases, the test solution diluted appropriately To measure the liquid according to 8.6 Therefore, Holmarde in the diluted solution The hide concentration can be determined.

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18 Single user license only. Copying and networking prohibited. This is subject to the END USER LINCENCE AGREEMENT.

Table with 4 columns: Current standard (JIS A 1460 : 2021), Old standard (JIS A 1460 : 2015), and Reason for revision. Rows include 9.7 Calibration curve, 9.8 Calculation, and 10 reports c) and i).

Licensed to PT. Mutuagung Lestari JSA Webdesk No.911033555 / Downloaded: 2021-11-18 Single user license only. Copying and networking prohibited. This is subject to the END USER LINCENCE AGREEMENT.

Table with 4 columns: Current standard (JIS A 1460 : 2021), Old standard (JIS A 1460 : 2015), and Reason for revision. Row includes 10 reports j) Cutting position of the test piece.

Annex A The test report was illustrated.
(Reference) Test
Report example

It was an optional item.
Regarding the test report, the users of the stan
This standard so that it can be recognized by tl
The test report of is illustrated in the annex.

Copyright law

By

Nothing
Duplex by decisive

Made, rolled

Listed
Etc. are prohibited

Being done

Oh
I will.

JIS A 1460 : 2021

Test method for formaldehyde emission of building boards- Desiccator method Explanation

This commentary explains what is specified and described in the standard, and is not a part of the standard.

This commentary is edited and published by the Japanese Standards Association, and the contact for inquiries regarding this is the Japanese Standards Association.

1 Background to this revision

This standard was established in 2001, and after the revision in 2015 (hereinafter referred to as the old standard), this revision was reached.

The process leading up to this amendment is as follows.

a) It was established as **JIS A 1460 in 2001** .

This standard has been tested in consideration of the international standardization of formaldehyde emission measurement method and the circumstances peculiar to Japan.
It was established as a test method standard. This test method is a method for measuring the amount of formaldehyde emitted into the air.
However, there are many years of measurement results and data accumulation in Japan, and building boards (hereinafter referred to as boards).
It's called kind.) It is a useful test method that can be executed relatively easily to ensure the quality of the product.

b) Revised in 2015 to unify related **ISO** standards and terms and definitions, symbols, units, formulas, etc. between **JIS**. went.

In this amendment, the **JIS** Development Committee and subcommittees have been conducting building material testing for three years from 2017.
Organized within the center. The committee and subcommittees will discuss and add types of desiccators.

Created a draft **JIS** revision.

2 Purpose of this amendment

Desiccator used when conducting tests according to the old standard [Call specified in " **JIS R 3503** (Glassware for chemical analysis)" It is stipulated that the size shall be 240 mm.] The domestic production has been discontinued, according to the relevant industry associations. If so, there is no prospect of future production. For this reason, an alternative desiccator (hereinafter referred to as an alternative product) Needed to be selected and verified and added to the standard.

Against this background, we selected and verified alternatives through a three-year national consignment project from 2017. Revised the standard.

In addition, we will discuss the contents that cause inconvenience in testing according to this standard, and if necessary, **JIS**. Created by reflecting it in the draft.

Solution 1

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

twenty two

A 1460: 2021 Explanation

3 Matters that were particularly problematic during the deliberation

The main matters and the results of the deliberation that became a problem in the deliberation of this standard are as follows.

a) Addition of substitutes for desiccators Discontinued desiccators (nominal dimensions specified in **JIS R 3503**)

240 mm. Hereinafter referred to as the current product.) To add a replacement to the standard, to a similar desiccator

I conducted a market research. As a result of the investigation, the product conforms to **ISO 13130** , Laboratory glassware-Desiccators.

Was available in Japan and was found to be distributed in Europe and the United States. In response to this, it complies with **ISO** standards.

If it is a product, it is considered that the quality is guaranteed, and it is possible to make an international match by quoting it.

A non-vacuum deci with a ball lid with a nominal diameter of 250 mm that complies with **ISO 13130** after deliberation.

Kata) was used as a substitute (reference [1]).

This is to confirm that there is no difference in the test results of formaldehyde emission between the current product and the alternative product.

The standard does not provide for round-robin testing, but it was conducted by 6 testing institutions. As a result, each trial

There is no statistically significant difference between the test results of the current product and the test results of the alternative product at the testing institution, and they are almost the same

For reference, it was confirmed that the difference between the test institutions was about $\pm 20\%$ of the total average value.

Dedication [2]). Efforts should be made to reduce the differences between testing institutions.

Use of substitutes for building boards other than the building boards tested in conjunction with the round-robin test

We verified whether it is possible to use it by numerical analysis for the purpose of theoretical support. resulting in,

If the measurement target is an internal diffusion-dominated building material, the effect of different desiccators is small, but transpiration-dominated.

In the case of mold-dissipating building materials, it was found to have an effect (reference [2]).

Most of the building materials measured by this standard are assumed to be internal diffusion controlled emission. However,

It cannot be said that there is no possibility of transpiration-dominated emission. Therefore, further numerical analysis is performed and an alternative product is used.

If this is the case, install a 25 mm thick glass plate under the glass crystal dish and raise it to support transpiration.

It was clarified that the influence of different desiccators can be reduced for the test target of distributed emission (reference).

Reference [3]).

In order to confirm the test results under the condition that the glass plate is installed in the substitute product, a comparative test between the substitute product and the current product is

It was carried out and the results were discussed. As a result of deliberation, the test result of formaldehyde emission amount is the current product.

It was concluded that the test results based on the above and the test results using the substitute product are almost the same (reference [3]).

Based on the above-mentioned deliberation on desiccator alternatives, the desiccator and bulk specified in **ISO 13130**.

The specifications and usage procedure of the glass plate for raising were specified and reflected in the **JIS** draft.

b) Response to the actual situation of domestic testing institutions Judging about the contents that cause inconvenience in testing according to this standard

We had a meeting. As a result of deliberation, the temperature of the test environment (change in tolerance), equipment (additional options), reagents (additional options),

Test time (change of allowable range), procedure for preparing calibration curve (change of volume range of solution, change of regulation of concentration range), report

The section (review of required items) was reviewed and reflected in the **JIS** draft.

Four Major amendments

The main amendments are as follows.

- a) Terms and definitions (Clause 3) To clarify the relationship between formaldehyde emission and formaldehyde concentration
Added definition of terms to. In addition, **JIS A 1902-1** is described as a source in the definition of boards .
- b) Principle of test (Clause 4) The desiccator specified in **ISO 13130** was added to the block diagram of the desiccator method .
In addition, since the formaldehyde content is measured by the absorptometry method, a color development similar to the measurement wavelength is added.
- c) Test environment (5.1) Regarding the temperature of the test piece during the curing and emission test, the applicable parts of Clause 8 and Clause 9 are specified.
I have decided. Here, the test location where other procedures (measurement of absorbance, etc.) are performed is specified.

Solution 2

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

twenty three

A 1460: 2021 Explanation

Therefore, ± 0.5 ° C was an excessive requirement. Within a temperature range sufficient for the analyzer to operate normally
It was changed to a certain ± 5 ° C.

- d) Common conditions (5.2) b) Water In the old standard, water of A1 to A4 specified in **JIS K 0557** was specified, but A1
Since the water used for cleaning appliances is used for cleaning equipment, the quality was set to A2 to A4 according to the actual situation.
- e) Equipment and fixtures (Clause 6) e) Desiccator Nominal dimension 240 mm specified in **JIS R 3503** specified in the old standard
Since the production of "desiccator" has been discontinued , the desiccator specified in **ISO 13130** is added as a substitute.
rice field. See Clause 3 of the commentary for the progress of deliberation on the addition of desiccators .
- f) Equipment and utensils (Clause 6) g) Glass plate Follow the regulations for the glass plate used for raising the glass crystal dish.
Added. The glass plate is used when the desiccator specified in **ISO 13130** is selected.
NS. See Clause 3 of the commentary for the reasons for using glass plates .
- g) Equipment and instruments (clause 6) h) Total volume flask The volume of the total volume flask is selected according to the volume of the liquid used.
Since it only needs to be determined, the capacity regulation has been deleted.
- h) Equipment and instruments (clause 6) i) Total pipette The volume of the total pipette should be selected according to the volume of the liquid used.
Since it only needs to be determined, the capacity regulation has been deleted. A piston pipette was added as an option.
- i) Equipment and instruments (clause 6) k) Flask with stopper The capacity of the flask with stopper matches the capacity of the liquid used.
Since it is only necessary to select them together, the capacity regulation has been deleted.
- j) Equipment and appliances (clause 6) m) Stainless steel wire mesh An allowable range was added to the diameter of the stainless steel wire mesh. diameter
If is smaller than 240 mm, it can be placed in a desiccator, so the allowable range was set to the smaller diameter side.
- k) Equipment and instruments (clause 6) n) Graduated cylinder A graduated cylinder was added to measure the volume of water.
- l) Preparation of reagents (Clause 7)) When reagents are prepared according to the volume specified in the old standard, most of the reagents are waste liquid.
It had to be processed. Therefore, considering the environmental impact of waste liquid treatment, the total amount of reagents can be changed.
I added it so that I could do it. However, for the formaldehyde standard solution, the measurement accuracy will be improved by changing the total amount.
Since the effect of is not negligible, the change in the total amount is not allowed.
- m) Preparation of reagents (Clause 7) a) **0.05 mol / L** iodine solution According to the old standard, 0.05 mol / L iodine solution should be prepared.
However, in the current standard, the solution prepared according to **JIS K 8001** is added as an option.
rice field. This made it possible to use commercially available reagents as iodine solutions for volumetric analysis.
- n) Preparation of reagents (Clause 7) b) **0.1 mol / L** sodium thiosulfate solution According to the old standard, the sodium thiosulfate solution is
It was only specified to prepare by mixing sodium thiosulfate pentahydrate and sodium carbonate, but now
In the line standard, the choice of preservatives is added, and the solution prepared as specified in **JIS K 8001** is selected.
Added as a limb. This makes it a commercially available reagent as a sodium thiosulfate solution for volumetric analysis.
And certified reference materials are now available.
- o) Preparation of reagents (Clause 7) c) **1 mol / L** sodium hydroxide solution According to the old standard, the sodium hydroxide solution is a hydroxide solution.
Although it was specified only to prepare using sodium chemicals, the current standard specifies the adjustment specified in **JIS K 8001**.
The prepared solution was added as an option. This makes it a sodium hydroxide solution for volumetric analysis.
Commercially available reagents can now be used.
- p) Preparation of reagents (clause 7) f) Formaldehyde standard stock solution In the old standard, titration after adding starch solution
Since the procedure was omitted, the procedure is specified in the current standard.
- q) Preparation of reagents (Clause 7) g) Formaldehyde standard solution In the old standard, the formaldehyde standard stock solution is adjusted.
Only titration was specified, but the current standard uses a formaldehyde standard solution with a JCSS certificate.
A diluted solution was also added so that it could be used as a standard formaldehyde stock solution.
The commercially available formaldehyde standard solution with JCSS certificate is titrated according to the old standard.
The uncertainty of concentration is larger than that of the case. Due to this effect, formaldehyde emission calculated by this standard

Solution 3

twenty four

A 1460: 2021 Explanation

It has been suggested that there is a slight effect on the uncertainty of the dose. Formaldehyde with JCSS certificate
Since the uncertainty of the concentration of the standard solution includes factors related to storage stability, the standard solution is used early after purchase.
By using, the variation in formaldehyde concentration during use can be made smaller than the indicated value of uncertainty.
It is presumed that.

- r) Preparation for test (9.1) Start of emission test (9.2) Procedure for preparation (cleaning and drying) and installation of glass plate
Was added. The height at which the glass crystal dish is raised by the glass plate is shown in **JIS R 3503** and **ISO 13130** .
It was set to 25 mm ± 2 mm based on the surface.

In addition, the capacity of water is measured with a measuring cylinder, and the capacity tolerance is specified in **JIS R 3505** .
Matched to Lath A.

In the old standard, the procedure and regulations for test preparation, mounting of the test piece on the test piece support hardware, and the start of the emission test
Since the order of the sentences was different, the procedure was rearranged according to the actual situation in the current standard.

- s) Test time (9.4) The allowable range of the test time of the old standard was ± 5 minutes, which was an excessive requirement. Therefore, Hol
The allowable range of test time was expanded to the extent that it did not affect the measurement of mualdehyde concentration. In addition, in the reference
Even at ISO 12460-4 : 2016, the allowable range of test time is ± 10 minutes.

- t) Measurement of formaldehyde concentration in test solution (9.6) According to the old standard, the volume of test solution was 25 mL.
However, most of them had to be treated as waste liquid. Therefore, from the viewpoint of reducing waste liquid, the capacity of the test solution should be adjusted.
The solution was changed from 5 mL to 25 mL so that the solution could be reduced within a range sufficient for measurement with a spectrophotometer.

- u) Preparation of calibration curve (9.7) Similar to the test solution, the volume of the calibration curve preparation solution is 25 mL to 5 mL to 25.
It was changed to mL so that the solution could be reduced within a range sufficient for measurement with a spectrophotometer.

In addition, the amount of formaldehyde emitted from building materials has generally decreased in recent years compared to when the standard was first established.
ing. For test solutions with low formaldehyde emission (low formaldehyde concentration)
If a calibration curve is created with the concentration specified in the old standard, there is a concern that the measurement accuracy of the concentration will decrease. Therefore, inspection
Allows the concentration range of formaldehyde solution for making quantity lines to be narrowed so that the measurement accuracy can be improved.
rice field.

- v) Calculation (9.8) The method of rounding the calculation result of formaldehyde concentration shall be Rule B of **JIS Z 8401** and rounded off.
Clarified that.

Also, when the two sets of formaldehyde concentrations are (0.1 mg / L, 0.2 mg / L) or (0.2 mg / L, 0.3 mg / L).
In addition, the difference is 20% or more of the average value. However, this difference is the smallest rounded to one decimal place.
The width. The difference in this case was recognized by adding the provision that "the difference is 0.2 mg / L or more".

- w) Report (Clause 10) The type of desiccator used was added to the required items of the test report. Also, density and trial
The cutting position of the test piece was changed from a required item to an optional item. Regarding the density, like the laminated lumber, the density
This is because there are many test pieces for which is not defined, and the cutting position of the test piece is within the range covered by this standard.
Because there is no such thing.

- x) Example of test report (Annex A) This so that users of the standard can gain a common understanding of the test report.
The test report of the standard is illustrated in the annex.

Five Concern

In 2008, **ISO 12460-4** : 2008, Wood-based panels-Determination of formaldehyde release-Part 4: Desiccator
A method (hereinafter referred to as **ISO** standard) was established. This **ISO** standard is JANS16 based on the Japanese desiccator method.
Made from the desiccator method (JANS: regional standard created in collaboration with Japan, Australia and New Zealand)
However, there are differences in the scope of application. Reexamine whether the **ISO** standard should be the corresponding international standard for this standard

Solution 4

twenty five

A 1460: 2021 Explanation

Was done.

The ISO standard covers particle board, fiber board, plywood, and oriented strand board (OSB).

And wooden flooring. On the other hand, this standard includes Japanese Agricultural Standard (JAS) wood-based boards and JIS A.

It is also quoted in 5440 [Volcanic Vitreous Multilayer Board (VS Board)] and covers all building boards.

There is a difference.

In addition, the number of digits displayed in the test results differs between the ISO standard and this standard. According to the ISO standard, the test result is only 0.01 mg / L. Although it is specified to be expressed in digits, this standard rounds it to one digit after the decimal point (0.1 mg / L unit).

As a result of deliberation on this point, we will make it consistent with the ISO standard based on the domestic situation (requirements in laws and regulations).

The unit was set to 0.1 mg / L as specified in the old standard.

Compliance with international standards is now related not only to the measurement accuracy of test piece collection and analysis, but also to domestic laws and regulations. I decided to send it as a later task.

6 Other commentary

The following are new supplements to the items specified in the old standard.

a) Temperature / humidity measuring device [Clause 6 a)] The accuracy of the thermometer and hygrometer specified in the main unit is the displayed value of each device.

Represents the minimum scale of (reading value).

b) Test preparation (9.1) "Multiple desiccators were adjusted to have an internal temperature of 20 ° C ± 0.5 ° C.

Place it in the test area. However, the tolerance of the internal temperature at this time is flat for 24 hours (radiation time).

It is a regulation for the average value, not for the time fluctuation.

c) Temperature (9.3.1) When measuring the temperature inside the desiccator, the heat generated by the thermometer causes the inside of the desiccator to generate heat.

There is concern that the temperature will be higher than the temperature in the test room. Be especially careful when using an electric thermometer

There is a need to.

d) Calculation (9.8) It is stipulated that the number of digits of formaldehyde concentration is rounded to one decimal place (0.1 mg / L unit).

However, in recent years, the number of products that emit less formaldehyde has increased compared to when the standard was first established. for that reason,

In the display of one digit after the decimal point, the significant digit is often one digit. Against this background, Holmardech

There was an opinion that the number of digits of the concentration should be changed to two digits after the decimal point (0.01 mg / L unit), but the following reasons

Therefore, the number of digits of formaldehyde concentration was left as one digit after the decimal point (0.1 mg / L unit).

-The measurement accuracy of the desiccator method is not so high.

-Formaldehyde concentration is a decimal point in product standards (JIS A 5905 , JIS A 5908, etc.) that cite this standard.

It must be clearly stated as one digit below.

7 References

[1] Consignment of Ministry of Economy, Trade and Industry 2017 Industrial standardization promotion business consignment cost High-performance JIS maintenance business (safe and secure s
JIS development that contributes to formation) Test method for formaldehyde emission of building boards (desiccator method)

JIS Development Results Report, February 2018, Building Materials Testing Center

[2] Consignment by Ministry of Economy, Trade and Industry FY2018 Industrial Standardization Promotion Project Consignment Cost Strategic International Standardization Acceleration Project
International standard development activities related to the test method of formaldehyde emission of building boards (desiccator method)

JIS Development Results Report, February 2019, Building Materials Testing Center

[3] Consignment by Ministry of Economy, Trade and Industry FY2019 Industrial Standardization Promotion Project Consignment Cost Strategic International Standardization Acceleration Project

Solution 5

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

26

A 1460: 2021 Explanation

International standard development activities related to the test method of formaldehyde emission of building boards (desiccator method)

JIS Development Results Report, February 2nd year of Reiwa, Building Materials Testing Center

8 Composition table of the drafting committee

The composition table of the drafting committee is shown below.

JIS A 1460 JIS Development Committee Composition Table

	Full name	Affiliation
(Chairman)	Shinichi Tanabe	Waseda University

(Committee)	Shinsuke Kato	The University of Tokyo Specially Appointed Professor
	Kazuhide Ito	Kyushu University
	Hideki Umejima	Living Products Division, Manufacturing Industries Bureau, Ministry of Economy, Trade and Industry
	Shohei Fukibuki	Building Guidance Division, Housing Bureau, Ministry of Land, Infrastructure, Transport and Tourism
	Yasuo Kuwasawa	National Institute for Land and Infrastructure Management, Ministry of Land, Infrastructure, Transport and Tourism
	Kota Miyamoto	National Research and Development Agency Forest Research and Management Organization Forest Comprehensive Laboratory
	Money Isao	National Institute of Public Health
	Hitomi Yoshida	General Incorporated Foundation Building Material Testing Center
	Rika Funaki	General Incorporated Association Building Performance Standards Promotion Association
	Shunichi Matsuda	Japan Building Materials and Housing Equipment Industry Association
	Takeji Ikeda	Japan Wall Covering Association
	Ken Hasegawa	Japan Textile Board Industry Association
	Kimura Western	Japan Federation of Construction Contractors
(Person concerned)	Nori Aoki Tomio	Japan Federation of Housing Organizations
	Koichi Sano	International Standards Division, Industrial Technology and Environment Bureau, Ministry of Economy, Trade and Ind
(Secretariat)	Yukio Takikawa	Japanese Standards Association
	Ikuko Miyazawa	General Incorporated Foundation Building Material Testing Center
	Kimura Rei	General Incorporated Foundation Building Material Testing Center
	Made by Ken Mabuchi	General Incorporated Foundation Building Material Testing Center

JIS A 1460 JIS Development Subcommittee Composition Table

	Full name	Affiliation
(Chief examiner)	Shinichi Tanabe	Waseda University
(Committee)	Shinsuke Kato	The University of Tokyo Specially Appointed Professor
	Kazuhide Ito	Kyushu University
	Hitomi Yoshida	General Incorporated Foundation Building Material Testing Center
	Makoto Ozeki	Japan Plywood Inspection Association
	Rika Funaki	General Incorporated Association Building Performance Standards Promotion Association
	Ken Hasegawa	Japan Textile Board Industry Association
(Person concerned)	Yusuke Izumida	International Standards Division, Industrial Technology and Environment Bureau, Ministry of Economy, Trade and Ind
(Secretariat)	Ikuko Miyazawa	General Incorporated Foundation Building Material Testing Center
	Kimura Rei	General Incorporated Foundation Building Material Testing Center
	Made by Ken Mabuchi	General Incorporated Foundation Building Material Testing Center

(Author JIS Development Committee)

Solution 6

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

★ JIS standard form and JIS inquiries about the standard form commentary, e-mail of the Association (E-mail: sd@jsa.or.jp),

Alternatively, please fax [(03) 4231-8660] or TEL [(03) 4231-8530]. Answer inquiries

In some cases, it may be necessary to confirm with the related parties, so it may take some time.

increase. Please note.

★ If a JIS standard errata is issued, we will inform you as follows.

(1) Errata (PDF version, download) on the Webdesk (<https://webdesk.jsa.or.jp/>) of the Japanese Standards Association group

Will be posted.

(2) For JIS additional members of this association, an errata was issued in the JIS department to which you applied.

If so, we will send it to you.

★ To order JIS standard slips, use the Japanese Standards Association Group's Webdesk (<https://webdesk.jsa.or.jp/>).

Please give me.

JIS A 1460

Test method for formaldehyde emission of building boards-desiccator method

February 22, 3rd year of Reiwa Issuance of the first printing

Editing and
Issuer **Yi Li Toshio**

Departure place

Japan Standards Association

〒108-0073 3-13-12 Mita, Minato-ku, Tokyo Mita MT Building
<https://www.jsa.or.jp/>Nagoya Branch 〒460-0008 2-6-1 Sakae, Naka-ku, Nagoya-shi RT Shirakawa Building
TEL (052) 221-8316 (Representative) FAX (052) 203-4806Kansai Branch 〒541-0043 3-2-7 Koraibashi, Chuo-ku, Osaka ORIX Inside the Koraibashi Building
TEL (06) 6222-3130 (Representative) FAX (06) 6222-3255Hiroshima Branch, 5-44 Motomachi, Naka-ku, Hiroshima 730-0011, Hiroshima Chamber of Commerce Building
TEL (082) 221-7023 FAX (082) 223-7568Fukuoka Branch 1-31 Tenyamachi, Hakata-ku, Fukuoka 812-0025 Hakata Urban Square
TEL (092) 282-9080 FAX (092) 282-9118

Printed in Japan

HE / B

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.

JAPANESE INDUSTRIAL STANDARD

**Determination of the emission of
formaldehyde from building boards-
Desiccator method**

JIS A 1460 : 2021

Revised 2021-02-22

Investigated by
Japanese Industrial Standards Committee

Published by
Japanese Standards Association

Price Code 08

ICS 13.040.99; 71.080.80; 79.060.10

Reference number : JIS A 1460 : 2021 (J)

Unauthorized reproduction, reprinting, etc. is prohibited by the copyright law.